

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015899
DATE: 11/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Lokabo
CODE: 2991-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Zhejiang Lokabo Intelligent Technology Co., Ltd. 26 East Yinxian Avenue, Yinzhou District, Ningbo, Zhejiang Province, China 315113	Series "N82" Aluminum Dual-Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1800mm(70.87") Sash: W-1153mm(45.39") H-1753mm(69.02") DLO: W-1047mm(41.22") H-1647mm(64.84")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 1200 x 1800 (47 x 71)-DAW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52psf)

Product Tested By: Intertek Testing Services Shenzhen Ltd.
Report No: 230704004SHF-002
Expiration Date: August 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023